

# **Compliance Statement**

No. 2020-869

Data communication cable, Category 6

### Company

Excel Excel House Junction Six Industrial park Electric Avenue Birmingham, B6 7JJ United Kingdom

#### **Product description**

Unscreened cable (U/UTP) characterised up to 250 MHz Horizontal floor wiring cable, 100  $\Omega$  4 twisted pairs Flame retardant, halogen free

### **Product identification**

190-071

## Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-6-1:2013
- TIA-568.2-D:2018

## Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12036715-02, DANAK-19/21624

**EC Cabling product ID** 6824

**CS valid until** 1 January 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 22 December 2020

Lars Lindskov Pedersen Test Manager

Lindska Pedana

Dormin Under

Dennis Andersen Head of Department



FORCE Technology Venlighedsvej 4 2970 Hørsholm Denmark Tel. +45 43 25 14 00 certification.madebydelta.com