

Compliance Statement

No. 2021-518

Screened Permanent Link, Class E_A

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Permanent Link Identification (3 connector model)

Horizontal cable:

100-196 Excel Category 6A Screened F/FTP "S" Foil Cable LS0H (EC VERIFIED)

RJ45 connector for telecommunications outlet, consolidation point and patch panel:

100-181 Excel Category 6A Low Profile Screened Keystone Jack – Toolless (EC VERIFIED)

Consolidation point cord:

100-133 Excel Category 6A Solid Core (F/FTP) screened harness/switch link leads (jack added)

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12125881-02, DANAK-19/22060

EC Cabling product ID


5673

CS valid until

1 August 2022

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 14 July 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

